

WTCI-48-P

W-4554 - FIDUCIARY TRUST INTERNATIONAL
1 WTC - 95th FLOOR - GENERAL
INSTRUCTION

REVIEW STATUS

[illegible]

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

M E M O R A N D U M

To: Mr. Julian Kau, General Manager,
Planning, Design & Construction, WT&ED
From: Ennala Ramabhushanam
Date: July 25, 1990
Subject: WTC - ALTERATION APPLICATION W-4554 - FIDUCIARY TRUST INTERNATIONAL -
1 WTC - 95TH FLOOR - GENERAL CONSTRUCTION

Reference: Review Request dated 7/11/90


Copy To: G. Gaeta R. Wegel Job Folder
L. Menno Chrono Folder

A review of the material submitted with the referenced request for the subject application has been made.

It is recommended that approval to proceed with construction be given subject to the submission of the items listed below being revised in accordance with the two (2) requirements listed on the attached rider.

Drawings:

- REMARKS: 1) Dwg. A-1, A-2 and A-3 dated 5/23/90, and Dwg. F-1-95, E-1, E-2 and E-3 dated 7/3/90, are recommended for approval.
- 2) This memorandum was transmitted to the Facility via OA, on July 25, 1990.


Ennala Ennala Ramabhushanam, P.E.
Manager
Quality Assurance Division

RAW/dm
att.

RIDER

ALTERATION APPLICATION W-4554

ARCHITECTURAL

1. Dwg. A-1, Elevation 4. Verify that glass panels within 18" of finished floor comply with requirements of N.Y.C. Building Code, Section C26-1011.9, Table 10-9 and RS 10-67.

ELECTRICAL

2. Show source of emergency power (e.g. storage battery packs) for all exit signs, to establish compliance with N.Y.C. Building Code C26-606.2.

072590

7/11

TENANT ALTERATION REVIEW REQUEST

ROUTING	ROOM NO.	Applicant's Name	Facility
Quality Assurance Paul Cooper	51N	FIDUCIARY TRUST INTERNATIONAL	WTC
In House	74		Dwg. No(s).
1 Rick Sorvillo			SEE ATTACHED SHEET
Charlie Semah			
Suren Batra			
1 R. PUCKER			
WT&ED Construction	3861	T.A.A. No. 4554	
1 P. CAVANAUGH		Contract No. 592.068	
		Location 1 WTC 95TH Date 7-11-90	
		Please review attached Application and forward comments to:	
Operations	B-2B	Attached are revised drawings. Please review.	
1 Tom Cancelliere		829 1 S. Rosenberg 74S 466-2514	
		Org. Unit Contact Rm. No. Ext.	
Risk Management			
1 John Foye (PATHSIDE)	4 FL		
Asbestos	JSTC	NOT LATER THAN 7-25-90	G. GAETA supervisor
1 Joseph Mullen		If no reply is received by above date, your concurrence will be assumed unless arrangements have been made for additional time.	

Description of Work: OPEN AREAS CLOSED TO
PRIVATE AREA

Construction Cost: \$40,000.00

General Construction

- | | | |
|---------------------------------------------------|------------------------------------------------|-----------------------------------------------|
| <input checked="" type="checkbox"/> Architectural | <input checked="" type="checkbox"/> Electrical | <input checked="" type="checkbox"/> HVAC |
| <input type="checkbox"/> Structural | <input checked="" type="checkbox"/> Plumbing | <input checked="" type="checkbox"/> Sprinkler |
| <input type="checkbox"/> Other _____ | | |

Submission No. 1

THE PORT AUTHORITY OF N.Y. & N.J.
TENANT CONSTRUCTION REVIEW UNIT

RECEIVED

JUL 12 1990

W-45540
ALTERATION APPLICATION

cc: C. Bianchi, E. Daly, J. Kau, G. GAETA
Project Coordinator S. Rosenberg

A. Preschle, G. Wenger, R. Wegel,

Louis J. Manno
Title Manager, Contract and Tenant Services Division

Date 7/12/90

2/20/90

July 3, 1990

PROJECT 95-008

Fiduciary Trust International
Two World Trade Center
Fiduciary Financial Services

<u>TITLE OF DRAWING</u>	<u>DWG. NO.</u>	<u>LATEST DUE</u>
Construction/Demolition Plan	A-1	5/23/90
Reflected Ceiling Plan	A-2	5/23/90
Occupancy Plan	A-3	7/3/90
Sprinkler Plan	F-1-95	7/3/90
Power Plan	E-1	7/3/90
Lighting Plan	E-2	7/3/90
Electrical Specifications	E-3	7/3/90